



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH

C2864a-0006(F).xls

DISTRIBUTION BOARD DB-1

REVISION F - 22 JULY 2026

FAULT CURRENT: 6kA CHASSIS SIZE: 2 X 84 POLES CHASSIS RATING: 250A PHASES: A MAIN SWITCH: 250A NON AUTO LOAD BREAK SUPPLIED FROM: MSB CABLE: 1C 120							REV
							A
							A
							A
							A
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE CONTROLS INCLUDING THE DYNALITE EQUIPMENT PROVIDED AS PART OF THE INITIAL WORKS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	GAMING	SIGN	A
P2	1	20	RCBO	2.5	GAMING	SIGN	A
P3	1	20	RCBO	2.5	GAMING	SIGN	A
P4	1	20	RCBO	2.5	GAMING	SIGN	A
P5	1	20	RCBO	2.5	GAMING	CLEANING	A
P6	1	20	RCBO	2.5	GAMING	POKER MACHINES	F
P7	1	20	RCBO	2.5	GAMING	VENDING	A
P8	1	20	RCBO	2.5	GAMING	TV	A
P9	1	20	RCBO	2.5	GAMING	POKER MACHINES	A
P10	1	20	RCBO	2.5	GAMING	POKER MACHINES	A
P11	1	20	RCBO	2.5	GAMING	POKER MACHINES	A
P12	1	20	RCBO	2.5	GAMING	POKER MACHINES	A
P13	1	20	RCBO	2.5	GAMING	POKER MACHINES	A
P14	1	20	RCBO	2.5	GAMING	POKER MACHINES	A
P15	1	20	RCBO	2.5	GAMING	MODEM	A
P16	1	20	RCBO	2.5		RACK H1	A
P17	1	20	RCBO	2.5		RACK H1	A
P18	1	20	RCBO	2.5		RACK H2	A
P19	1	20	RCBO	2.5		RACK H2	A
P20	1	20	RCBO	2.5		RACK H3	A
P21	1	20	RCBO	2.5		RACK H3	A
P22	1	20	RCBO	2.5		RACK H4	A
P23	1	20	RCBO	2.5		RACK H4	A
P24	1	20	RCBO	2.5	EXTERNAL	GPO	A
P25	1	20	RCBO	2.5	EXTERNAL	PUMP	A
P26	3	20	RCBO	2.5		RSD	A
P27	1	20	RCBO	2.5		HWS	A
P28	1	20	RCBO	2.5		CLEANING	A
P29	1	20	RCBO	2.5		CLEANING	A
P30	1	20	RCBO	2.5		AUTODOOR	A
P31	1	20	RCBO	2.5		TV	A
P32	1	20	RCBO	2.5		LED SCREEN	A
P33	1	20	RCBO	2.5		SRT	A
P34	1	20	RCBO	2.5		ATM	A
P35	1	20	RCBO	2.5		ATM	A
P36	1	20	RCBO	2.5		AUTODOOR	A
P37	3	50		10.0		28KW HWS	A
P38	1	20	RCBO	2.5		LED SCREEN	A
P39	1	20	RCBO	2.5		TV	A
P40	1	20	RCBO	2.5		CLEANING	A
P41	1	20	RCBO	2.5	EXTERNAL	GPO	A
P42	1	20	RCBO	2.5		HD	A
P43	1	20	RCBO	2.5		HD	A
P44	3	50		10.0		28KW HWS	A
P45	1	20	RCBO	2.5		AUTO DOOR	A
P46	1	20	RCBO	2.5		CLEANING	A
P47	1	20	RCBO	2.5	LOADING	POST MIX	A
P48	1	20	RCBO	2.5	LOADING	POST MIX	A
P49	1	20	RCBO	2.5	LOADING	ICE MACHINE	A

C2864a-0006(F).xls

Pages inc. any attach. 1 of 3



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH

C2864a-0006(F).xls

DISTRIBUTION BOARD DB-1

REVISION F - 22 JULY 2026

FAULT CURRENT: 6kA CHASSIS SIZE: 2 X 84 POLES CHASSIS RATING: 250A PHASES: A MAIN SWITCH: 250A NON AUTO LOAD BREAK SUPPLIED FROM: MSB CABLE: 1C 120							REV
							A
							A
							A
							A
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE CONTROLS INCLUDING THE DYNALITE EQUIPMENT PROVIDED AS PART OF THE INITIAL WORKS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P50	1	20	RCBO	2.5	BAR	GPOs	A
P51	1	20	RCBO	2.5	BAR	GLASS WASHER	A
P52	1	20	RCBO	2.5	BAR	POS	A
P53	1	20	RCBO	2.5	EXTERNAL	SOLOIST	A
P54	1	20	RCBO	2.5	EXTERNAL	SOLOIST	A
P55	1	20	RCBO	2.5	KEG ROOM	BEER	A
P56	1	20	RCBO	2.5	KEG ROOM	BEER	A
P57	1	20	RCBO	2.5	KEG ROOM	GLYCOL	A
P58	1	20	RCBO	2.5	KEG ROOM	COMPRESSOR	A
P59	3	20	RCBO	2.5	EXTERNAL	GLYCOL	E
P60	1	20	RCBO	2.5	GAMING	GPO	A
P61	1	20	RCBO	2.5	GAMING	COFFEE	A
P62	1	20	RCBO	2.5	GAMING	REF	A
P63							F
P64	1	32		6.0	EXTERNAL	INVERTER	A
P65	1	20	RCBO	2.5	TAB	TV	A
P66	1	20	RCBO	2.5	EXTERNAL	TV	A
P67	1	20	RCBO	2.5	GAMING	LOUVRES	A
P68	1	20	RCBO	2.5		HEATER	D
P69	1	20	RCBO	2.5		HEATER	D
P70	1	20	RCBO	2.5		HEATER	D
P71	1	20	RCBO	2.5		HEATER	D
P72	1	20	RCBO	2.5		HEATER	D
P73	1	20	RCBO	2.5		HEATER	D
P74	1	20	RCBO	2.5	ENTRY	LED SCREEN	A
P75	1	20	RCBO	2.5	EXTERNAL	WATER FEATURE	B
P76	1	20	RCBO	2.5		HEATER	D
P77	1	20	RCBO	2.5		HEATER	D
P78	1	20	RCBO	2.5		HEATER	D
P79	1	20	RCBO	2.5		HEATER	D
P80	1	20	RCBO	2.5		HEATER	D
P81	1	20	RCBO	2.5		HEATER	D
P82	1	20	RCBO	2.5		HEATER	D
P83	1	20	RCBO	2.5		HEATER	D
P84	1	20	RCBO	2.5		HEATER	D
P85	1	20	RCBO	2.5		HEATER	D
P86	1	20	RCBO	2.5		HEATER	D
P87	1	20	RCBO	2.5		HEATER	D
P88	1	20	RCBO	2.5		HEATER	D
P89	1	20	RCBO	2.5		HEATER	D
P90	1	20	RCBO	2.5		HEATER	D



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH

C2864a-0006(F).xls

DISTRIBUTION BOARD DB-1

REVISION F - 22 JULY 2026

FAULT CURRENT: 6kA CHASSIS SIZE: 2 X 84 POLES CHASSIS RATING: 250A PHASES: A MAIN SWITCH: 250A NON AUTO LOAD BREAK SUPPLIED FROM: MSB CABLE: 1C 120							REV
							A
							A
							A
							A
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE CONTROLS INCLUDING THE DYNALITE EQUIPMENT PROVIDED AS PART OF THE INITIAL WORKS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
L1	1	20	RCBO	2.5	HOTEL	CASINO LIGHT	C
L2	1	20	RCBO	2.5	HOTEL	SIGN	A
L3	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L4	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L5	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L6	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L7	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L8	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L9	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L10	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L11	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L12	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L13	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L14	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L15	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L16	1	20	RCBO	2.5	HOTEL	LIGHTS	A
L17	1	20	RCBO	2.5	HOTEL	FANS	A
L18	1	20	RCBO	2.5	HOTEL	FANS	A