



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

**C3354a - ASPLEY LEAGUES CLUB - GAMING REFURBISHMENT**

**C3354a-0002(F).xls**

## ELECTRICAL EQUIPMENT SCHEDULE

**REVISION F - 04 SEPTEMBER 2025**

**THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK**  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1		TAKE POSSESSION OF DECORATIVE PENDANTS FROM THE CLIENT AND INSTALL. THE FITTING TYPES ARE THE SAME AS THE L6 FITTINGS. CONFIRM THE SUSPENSION LENGTH ON SITE WITH THE ARCHITECT.			A
L2		TAKE POSSESSION OF DECORATIVE PENDANTS FROM THE CLIENT AND INSTALL EACH L2 AS A TIGHT GROUP OF THREE. THE FITTING TYPES ARE THE SAME AS THE L6 FITTINGS. CONFIRM THE SUSPENSION LENGTHS ON SITE WITH THE ARCHITECT.			A
L3	3000K LED	55DEG RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	BLACK	GAMMA ILLUMINATION CIMI 1094-VWFL-3K-22W	A
L4	4000K LED	AMENITY RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE	GAMMA ILLUMINATION MYLO 1004-4K-13W	A
L5	3000K 3W 240VOLT TE DIMMABLE G9 LAMP	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	AGED BRASS	LIGHTERIOR EVIE WALL LIGHT	A
L6	3000K 3W 240VOLT TE DIMMABLE G9 LAMP PER FITTING	DECORATIVE PENDANT. PROVIDE EACH L6 AS A CLUSTER OF THREE FITTINGS. CONFIRM THE SUSPENSION LENGTHS ON SITE WITH THE ARCHITECT.	BRASS	3 X CARIBOU CONTINA SKU: NLX6N2113153035	B
L7		EXISTING RECESSED DOWNLIGHT TO REMAIN AS IS			D
L8		EXISTING RECESSED DOWNLIGHT TO BE RELOCATED AS INDICATED. THE EXISTING SUPPLY AND CONTROL IS TO BE RETAINED.			D
L9		PROVIDE A NEW RECESSED DOWNLIGHT TO MATCH THE EXISTING L7 FITTING. UTILISE THE EXISTING L7 FITTINGS SUPPLY AND CONTROL.			D
L10		PROVIDE A NEW RECESSED DOWNLIGHT TO MATCH THE EXISTING L7 FITTING. UTILISE THE EXISTING CASH ROOM 2 SWITCH AND CIRCUIT TO SUPPLY THE NEW L10 FITTINGS. REMOVE ALL OF THE EXISTING CASH ROOM 2 LIGHTS.			E
S1	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED BEHIND THE WALL FEATURE AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE S1 WITH A REMOTE DALI DIMMABLE POWER SUPPLIES LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
S2	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER WITHIN THE CASHIER COUNTER AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE S2 WITH A REMOTE DALI DIMMABLE POWER SUPPLIES LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3354a - ASPLEY LEAGUES CLUB - GAMING REFURBISHMENT


C3354a-0002(F).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION F - 04 SEPTEMBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S3	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED WITHIN THE REAR BAR JOINERY AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE S3 WITH A REMOTE DALI DIMMABLE POWER SUPPLIES LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
S4	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED WITHIN THE PROMO JOINERY AS PER THE SECTION AND THE ARCHITECTURAL DETAIL. PROVIDE THE S4 WITH A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
S5	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED WITHIN THE PROMO JOINERY AS PER THE SECTION AND THE ARCHITECTURAL DETAIL. PROVIDE THE S5 WITH A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
S6	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE S6 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-VWW + POWER SUPPLY & DALI CONTROLLER	A
S7	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED WITHIN THE TV SCREEN JOINERY AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF S7 LED WITH A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
S8	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED WITHIN THE SHELF AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE S8 WITH A REMOTE DALI DIMMABLE POWER SUPPLIES LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	E



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3354a - ASPLEY LEAGUES CLUB - GAMING REFURBISHMENT

C3354a-0002(F).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION F - 04 SEPTEMBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S9	880LM /M 3000K 24V LED	LED STRIP LIGHT FIXED IN PLACE BEHIND THE TVS WITH DOUBLE SIDED INDUSTRIAL STRENGTH TAPE TO CREATE A HALO AROUND ALL EXTERNAL EDGES OF THE TVS. CONFIRM THE SIZE OF THE TVS WITH THE ARCHITECT. PROVIDE THE S9 WITH A REMOTE DALI DIMMABLE POWER SUPPLIES LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. ALL CABLING FROM THE LED STRIP TO THE DRIVER MUST BE CONCEALED.	NATURAL	MELEC ML-VLCRI-14.4 WW	F
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS LLIFEBLK	A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	BLACK	CLEVERTRONICS LUBPRO-SM BLK	A
CEILING FAN (F1)		1300 DIA LOW PROFILE CEILING FAN C/W A REMOTE CONTROLLER	WHITE AIRFOIL WHITE HARDWARE	BIGG ASS HAIKU COASTAL 1.3DIA LOW PROFILE C/W REMOTE CONTROLLER MK-HKC1-0402506A824F824105(S2)	D
HEATER (H1)		40000w AREA HEATER PROVIDE EACH HEATER WITH REMOTE WIRELESS CONTROL. CONFIRM THE LOCATION OF THE CONTROLLER ON SITE WITH THE ARCHITECT	BLACK HEATER AND MOUNTING	BROMIC 2620264-2 + CONTROLLER	D
LIGHTING CONTROL SWITCH PANEL (SP)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	BLACK	DYNALITE ANTUMBRA DISPLAY	A
LIGHTING CONTROL PRESENCE DETECTOR (PD)		ADJUSTABLE FLUSH RECESSED 360 DEGREE PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	WHITE	CLIPSAL	B
TRAILING EDGE MANUAL POT DIMMER (DIM)		400W 240 VOLT TRAILING EDGE MANUAL POT DIMMER MOUNTED WITHIN THE DB-G ESCUTCHEON. ENSURE THE DIMMERS ARE COMPATIBLE WITH THE L5 AND L6 LAMPS			A

C3354a-0002(F).xls

Pages inc. any attach. 3 of 5



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

## C3354a - ASPLEY LEAGUES CLUB - GAMING REFURBISHMENT

C3354a-0002(F).xls

### ELECTRICAL EQUIPMENT SCHEDULE

REVISION F - 04 SEPTEMBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	OUTLETS EXPOSED TO PATRON VIEW BLACK CONCEALED OUTLETS WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	OUTLETS EXPOSED TO PATRON VIEW BLACK CONCEALED OUTLETS WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET (USB)		DOUBLE POWER OUTLET C/W USB A AND USB C CHARGER , CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT ABOVE BENCH. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	D
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
DB-G		PROVIDE A NEW DISTRIBUTION BOARD DB-G AS PER THE NOTES AND DB-G SCHEDULE. COLOUR GREY HINGED ESCUTCHEON C/W 1/4 TURN LATCHES AND D HANDLES. PROVIDE A SHOP DRAWING OF DB-G FOR APPROVAL.			B
DB-E		EXISTING DISTRIBUTION BOARD (DB-E) TO BE NAMED DB-E. PROVIDE NEW LABELLING ON THE DB AND IN THE MSB. ALL CIRCUITS THAT BECOME REDUNDANT ARE TO BE REMOVED AND THE SCHEDULE UPDATED AT PRACTICAL COMPLETION.			B
COMMUNICATIONS RACK (CR-1)		EXISTING COMMUNICATIONS RACK CR-1 TO BE REMOVED. REDIRECT THE EXISTING CR-1 SUPPLY SERVICES TO THE NEW CR-A.			A
COMMUNICATIONS RACK (CR-2)		EXISTING COMMUNICATIONS RACK CR-2 TO BE REMOVED. REDIRECT THE EXISTING CR-2 SUPPLY SERVICES TO THE NEW CR-A.			A
COMMUNICATIONS RACK (CR-A)		PROVIDE A NEW FULL HEIGHT 800 DEEP COMMUNICATIONS RACK CR-A WITH THE REQUIRED CAT 6 PATCH PANELS TO FACILITATE THE COMMUNICATIONS OUTLETS AND TIE CABLES. PROVIDE CR-A WITH A 12 X 10 AMP PORT FIXED POWER RAIL, A PERFORATED LOCKABLE DOOR, CASTERS AND LOCKABLE REMOVABLE SOLID SIDES.			A
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-3 VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	OUTLETS EXPOSED TO PATRON VIEW BLACK CONCEALED OUTLETS WHITE	CLIPSAL C2000 SERIES	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3354a - ASPLEY LEAGUES CLUB - GAMING REFURBISHMENT

C3354a-0002(F).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION F - 04 SEPTEMBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SERVICES DROPPER (SD)		PROVIDE EACH ELECTRICAL SERVICES DROPPER AS A ROUND (LESS THAN 100MM DIA) TWO CHANNEL POWDER COATED POLE FROM THE GAMING BASE TO THE CEILING TO PROVIDE POWER AND COMMUNICATIONS CABLING ACCESS FROM THE CEILING TO THE GAMING MACHINE BASE. PROVIDE A FLANGE AROUND THE POLE TO CONNECT IT TO THE BASE AND TO THE CEILING. THE ARCHITECT WILL CONFIRM THE COLOUR. (ALLOW FOR BLACK) SUBMIT DETAILS OF THE PROPOSED POLE FOR APPROVAL.			A
GAMING FIBRE (GF)		INSTALL DUPLEX FIBRE OPTIC CABLE BETWEEN THE POKER MACHINE BASES AND FROM THE POKER MACHINE BASES BACK TO RACK CR-A AS INDICATED. THE DUPLEX FIBRE OPTIC CABLE WILL BE SUPPLIED AND TERMINATED BY OTHERS.			A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
FIRE ALARM SPEAKER		PROVIDE A RECESSED FIRE ALARM SPEAKER C/W A BLACK GRILL UNLESS NOTED AS WHITE CONNECTED TO THE EXISTING FIRE ALARM SYSTEM.			C