



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3358a - BRACKEN RIDGE TAVERN

C3358a-0005(D).xls

DISTRIBUTION BOARD DB-1

REVISION D - 13 JANUARY 2026

UPGRADE THE EXISTING DISTRIBUTION BOARD AS REQUIRED TO ACCOMMODATE THE FOLLOWING CIRCUITS. REMOVE ALL EXISTING SWITCHGEAR MADE REDUNDANT BY THE WORKS. UPDATE THE SWITCHBOARD LABELS AND SCHEDULE AT PRACTICAL COMPLETION							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE ( mm <sup>2</sup> )	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5		AUTO DOOR	B
P2	1	20	RCBO	2.5		TV	B
P3	1	20	RCBO	2.5		LOYALTY MACHINE	B
P4	1	20	RCBO	2.5	BAR	TV	B
P5	1	20	RCBO	2.5	BAR	REF	B
P6	1	20	RCBO	2.5	BAR	GLASS CHILLER	B
P7	1	20	RCBO	2.5	BAR	GPO	B
P8							D
P9	1	20	RCBO	2.5	BAR	POS	B
P10	1	20	RCBO	2.5	BAR	GLASS CHILLER	B
P11	1	20	RCBO	2.5	BOH	GPO	B
P12	1	20	RCBO	2.5	SPORTS BAR	PROJECTOR	C
P13							B
P14							B
P15							B
P16							B
P17							B
L1	1	20	RCBO	2.5		LIGHTS	A
L2	1	20	RCBO	2.5		LIGHTS	A
L3	1	20	RCBO	2.5		LIGHTS	A
L4	1	20	RCBO	2.5		LIGHTS	A
L5	1	20	RCBO	2.5		LIGHTS	A
L6							B
L7							B
L8							B
L9							B
L10							B