



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3358a - BRACKEN RIDGE TAVERN

C3358a-0007(E).xls

DISTRIBUTION BOARD DB-C

REVISION E - 04 FEBRUARY 2026

UPGRADE THE EXISTING DISTRIBUTION BOARD AS REQUIRED TO ACCOMMODATE THE FOLLOWING CIRCUITS. REMOVE ALL EXISTING SWITCHGEAR MADE REDUNDANT BY THE WORKS. UPDATE THE SWITCHBOARD LABELS AND SCHEDULE AT PRACTICAL COMPLETION							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	FUNCTION ROOM	TV	A
P2	1	20	RCBO	2.5	FUNCTION ROOM	CLEANING	A
P3	1	20	RCBO	2.5	KITCHEN	GLASS WASHER	C
P4	1	20	RCBO	2.5	KITCHEN	GLASS WASHER	C
P5	3	32	RCBO	6.0	KITCHEN	16.7KW DW	A
P6	1	20	RCBO	2.5	KITCHEN	GLASS WASHER	C
P7	1	20	RCBO	2.5	KITCHEN	GLASS WASHER	C
P8	1	20	RCBO	2.5	ENTRY	KIOSK	D
P9	1	40		6.0	ROOF	AIR CONDITIONER	E
P10	1	40		6.0	ROOF	AIR CONDITIONER	E
P11							B
P12							B
P13							B
P14							B
P15							B
P16							B
P17							B
L1	1	20	RCBO	2.5	FUNCTION ROOM	LIGHTS	A
L2	1	20	RCBO	2.5	FUNCTION ROOM	LIGHTS	A
L3							B
L4							B
L5							B
L6							B
L7							B
L8							B
L9							B
L10							B