



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3358a - BRACKEN RIDGE TAVERN

C3358a-0006(D).xls

DISTRIBUTION BOARD DB-B (GROUND SOUTH)

REVISION D - 11 JULY 2025

							REV
FAULT CURRENT:		6KA USING CASCADING			MAIN SWITCH:		250A NON AUTO LOAD BREAK MSB 4C70
CHASSIS SIZE:		2 X 60 POLES			SUPPLIED FROM:		
CHASSIS RATING:		250A			SUPPLY CABLE:		
PHASES:		3					
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE INITIAL PHILIPS DYNALITE CONTROLS .							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE ( mm <sup>2</sup> )	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5		CLEANING	B
P2	1	20	RCBO	2.5		STAGE	B
P3	1	20	RCBO	2.5		STAGE	B
P4	1	20	RCBO	2.5		STAGE	B
P5	1	20	RCBO	2.5		CLEANING	B
P6	1	20	RCBO	2.5		TV	B
P7	1	20	RCBO	2.5		AUTO DOOR	B
P8	1	20	RCBO	2.5		MEET & GREET	B
P9	1	20	RCBO	2.5		CLEANING	B
P10	1	20	RCBO	2.5		KENO	B
P11	1	20	RCBO	2.5		TV	B
P12	1	20	RCBO	2.5		WAIT STATION	B
P13	1	20	RCBO	2.5		STAGE	B
P14	1	20	RCBO	2.5		STAGE	B
P15	1	20	RCBO	2.5		STAGE	B
P16	1	20	RCBO	2.5	BAR	BUMP SCREEN	D
P17	1	20	RCBO	2.5	BAR	BUMP SCREEN	D
P18	1	20	RCBO	2.5	BAR	GPO	B
P19	1	20	RCBO	2.5	BAR	DISPLAY	B
P20	1	20	RCBO	2.5	BAR	REF	B
P21	1	20	RCBO	2.5	BAR	POS	B
P22	1	20	RCBO	2.5	BAR	COFFEE	B
P23	1	20	RCBO	2.5	BAR	TV	B
P24	1	20	RCBO	2.5	BAR	REF	B
P25	1	40	RCBO	6.0	BAR	40A HWS	D
P26	1	20	RCBO	2.5	BAR	REF	B
P27	1	20	RCBO	2.5	BAR	REF	B
P28	1	20	RCBO	2.5	BAR	REF	B
P29	1	20	RCBO	2.5	BAR	POS	B
P30	1	40	RCBO	6.0	BAR	40A HWS	D
P31	3	20	RCBO	2.5	BAR	WASH	D
P32	1	40	RCBO	6.0	BAR	40A HWS	D
P33							D

**C3358a - BRACKEN RIDGE TAVERN**

**C3358a-0006(D).xls**

### DISTRIBUTION BOARD DB-B (GROUND SOUTH)

REVISION D - 11 JULY 2025

[illegible]