



EXISTING ELECTRICAL FLOOR & WALL SERVICES WITHIN THIS DASH LINED AREA TO BE REMOVED , UNLESS NOTED OTHERWISE.

PROVIDE THESE OUTLETS LOOSE AT 1000AFL LOCATED BEHIND THE LED SCREEN WITH THE ABILITY TO BE PUSHED BACK INTO THE WALL CAVITY. PROVIDE THE COMMUNICATIONS OUTLETS WITH MALE PLUGS AND 2M OF SLACK CABLE. COORDINATE THE POSITION ON SITE WITH THE LED SCREEN SUPPLIER.

CIRCUIT AND SWITCH THIS FLOOR LEVEL LED STRIP LIGHT WITH THE (LL1-1) FITTINGS SHOWN ON DRAWING C3403a-E04.