



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3419a - PRINCE OF WALES HOTEL, NUNDAH					C3419a-0002(E).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION E - 28 OCTOBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	13W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION MYLO 1004-FL-3K-13W	A
L2	22W 3000K LED	RECESSED DOWNLIGHT WITH A NEW RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	BLACK	EQUAL TO GAMMA ILLUMINATION ZYLO 1003-VWFL-3K-22W	B
L3	22W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION ZYLO 1003-VWFL-3K-22W	A
L4	EXISTING RECESSED DOWNLIGHT LIGHT TO REMAIN AND BE RECIRCUITS / SWITCHED AS INDICATED				A
L5	13W 3000K LED	SURFACE MOUNTED DOWNLIGHT C/W INTEGRAL DALI DIMMABLE DRIVER ALLOW TO CHASE IN ALL CABLING AND CONDUITS	BLACK	EQUAL TO GAMMA ILLUMINATION SOLO 1412-3K-13W	B
L6	13W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION SCOOP MINI 1495-FL-3K-13W	A
L7	8W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION CIBA 1218-FL-3K-8W	A
L8	EXISTING LIGHT TO REMAIN AND BE RECIRCUITS / SWITCHED AS INDICATED				A
L9	40W 4000K LED	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PLASTER BOARD KIT	WHITE TRIM	GAMMA ILLUMINATION PHANTOM 884502	A
L10	13W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION RHO 1001-3K-13W	B
PD01	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 1200 LUMENS +/- 10% 15,000 HOUR LIFE	DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK	FAT SHACK VINTAGE INDUSTRIAL WAREHOUSE CHAIN PENDANT SKU: P302-TCHNW-LRG-BLK	B
PD02	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 1200 LUMENS +/- 10% 15,000 HOUR LIFE	DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	COPPER	FAT SHACK VINTAGECONE LOOP PENDANT SKU P1187-LOPB-LRG-CPR	C



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3419a - PRINCE OF WALES HOTEL, NUNDAH

C3419a-0002(E).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION E - 28 OCTOBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PD03	PROVIDE SIX TRAILING EDGE DIMMABLE E14 240 VOLT 2700K 600 LUMENS +/- 10% 15,000 HOUR LIFE	SEVEN LAMP DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	SATIN BRASS	EARLY SETTLER KEMPSEY SATIN BRASS 7 BALL LIGHT PENDANT SKU: 90023599	B
PD04	PROVIDE SIX TRAILING EDGE DIMMABLE E14 240 VOLT 2700K 600 LUMENS +/- 10% 15,000 HOUR LIFE	SIX LAMP DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	SATIN BRASS	EARLY SETTLER ASPEN SATIN BRASS 6 LIGHT PENDANT SKU: 90015717	B
PD05	TRAILING EDGE DIMMABLE 240 VOLT 2700K E14 FILAMENT LED 250 LUMENS +/- 10% 150,000 HOUR LIFE	380 DIA DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK WITH BRONZE DETAIL	BEACON LIGHTING 18380	E
WL01	TRAILING EDGE DIMMABLE 3W 3000K GX53 240 VOLT	WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	AGED BRONZE	BEACON LIGHTING SIENNA 1 CODE 309202	C
WL02	4W 3000K LED	WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	CLEAR	LUCREATIA AQUALIGHT WALL LIGHT SKU: LUW41371/135	B
S1	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE COUNTER PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE S1 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW- VWW + POWER SUPPLY & DALI CONTROLLER	A
S2	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED IN THE REAR BAR JOINERY AS PER THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF S2 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407- 2M - ML-VLCRI-14.4- WW	A
S3	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED IN THE GAMING CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF S3 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407- 2M - ML-VLCRI-14.4- WW	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3419a - PRINCE OF WALES HOTEL, NUNDAH

C3419a-0002(E).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION E - 28 OCTOBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S4	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED HARD AGAINST THE SPLASH BACK UNDER THE OVERHEAD CUPBOARDS AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE S4 WITH A REMOTE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
S5	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED BEHIND THE TV ALONG ALL FOUR SIDES AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE S5 WITH A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	B
BL01	ALLOW A PC SUM OF \$5,000.00 PLUS GST TO SUPPLY AND INSTALL TREE BUD LIGHTS IN EACH BL01 POSITION.				A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	C
E2	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS LLIFEBLK	C
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE UNLESS NOTED AS BK THEN BLACK BODY	CLEVERTRONICS LUBPRO-SM	C
F01	CEILING FAN	132 DIA DC MOTOR CEILING FAN. PROVIDE THE F01 WITH A DEDICATED WIRED CONTROLLER CONFIRM THE DROP ON SITE WITH THE ARCHITECT	BLACK	BIG ASS FANS HAIKU MK-HK4-04	A
FAN CONTROLLER TYPE 1 (FC1)		FAN ON / OFF / SPEED CONTROLS. WALL MOUNTED AT 1000 AFFL	WHITE	TYPE TO MATCH THE FAN	A
HEATER TYPE 1 (HR01)		2300W WALL MOUNTED HEATER C/W MOUNTING BRACKET AND REMOTE CONTROL LOCATED ADJACENT SP4	BLACK	BROMIC PLATINUM SMART ELECTRIC	A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3419a - PRINCE OF WALES HOTEL, NUNDAH					C3419a-0002(E).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION E - 28 OCTOBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK					
<a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TWO-WAY LIGHT SWITCH		TWO-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
LIGHTING CONTROL SWITCH PANEL (SPx)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE	CLIPSAL C2000 SERIES 30USM	B
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET AUTO DOOR (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED CONCEALED WITHIN THE AUTO DOOR MULLION. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	-	CLIPSAL WSCF227F	B
SPECIAL PURPOSE OUTLET		SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.			A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A



# ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3419a - PRINCE OF WALES HOTEL, NUNDAH					C3419a-0002(E).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION E - 28 OCTOBER 2025					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK <a href="http://www.edg.net.au/Links/Lighting.htm">www.edg.net.au/Links/Lighting.htm</a>					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
GAMING ROOM JUNCTION BOX		PROVIDE A SQUARE PLASTIC JUNCTION BOX CHASED INTO THE SLAB WITH THE TOP FLUSH WITH THE FLOOR. THE GAMING POWER CONDUITS ARE TO RUN TO A POWER JUNCTION BOX AND THE GAMING COMMUNICATIONS CONDUITS ARE TO RUN TO A COMMUNICATIONS JUNCTION BOX. LOCATE THE JUNCTION BOXES UNDER THE GAMING MACHINES.			A
COMMUNICATIONS RACK CR-A		COMMUNICATIONS RACK CR-A BY OTHERS			A
DB-A		DISTRIBUTION BOARD DB-A AS PER THE DB-A SCHEDULE AND NOTES. PROVIDE A SHOP DRAWING OF DB-A FOR APPROVAL. PROVIDE A REMOVABLE FLANGED COLOUR BOND HAT SECTION THE SAME WIDTH AND DEPTH AS THE DB FROM THE FLOOR TO THE UNDERSIDE OF THE DB AND FROM THE TOP OF THE DB TO THE CEILING. PROVIDE DB-A WITH A 4C+E16MM SUBMAIN FROM DB-1 PROTECTED BY A THREE PHASE 63 AMP MCB.			D
DB-B		DISTRIBUTION BOARD DB-B AS PER THE DB-B SCHEDULE AND NOTES. PROVIDE A SHOP DRAWING OF DB-B FOR APPROVAL. PROVIDE A REMOVABLE FLANGED COLOUR BOND HAT SECTION THE SAME WIDTH AND DEPTH AS THE DB FROM THE FLOOR TO THE UNDERSIDE OF THE DB AND FROM THE TOP OF THE DB TO THE CEILING. PROVIDE DB-B WITH A 4C+E16MM SUBMAIN FROM DB-2 PROTECTED BY A THREE PHASE 63 AMP MCB.			D
DB-K		EXISTING DISTRIBUTION BOARD TO REMAIN AS IS.			A
DB-G		REMOVE THE EXISTING DB-G AND RECONNECT ALL REMAINING CIRCUITS TO DB-1 OR DB-2 WITH NEW SWITCHGEAR AND CONTROLS MATCHING THE EXISTING IN CAPACITY AND FUNCTION.			A
DB-R		REMOVE THE EXISTING DB-R AND RECONNECT ALL REMAINING CIRCUITS TO DB-1 OR DB-2 WITH NEW SWITCHGEAR AND CONTROLS MATCHING THE EXISTING IN CAPACITY AND FUNCTION.			A
DB-T		REMOVE THE EXISTING DB-T AND RECONNECT ALL REMAINING CIRCUITS TO DB-1 OR DB-2 WITH NEW SWITCHGEAR AND CONTROLS MATCHING THE EXISTING IN CAPACITY AND FUNCTION.			A
DB-1		EXISTING DISTRIBUTION BOARD TO REMAIN REMOVE ALL EXISTING CIRCUITS AND ASSOCIATED CABLING THAT BECOMES REDUNDANT DUE TO THE PROPOSED WORKS. UPDATE THE EXISTING LABELLING AND SCHEDULE AT PRACTICAL COMPLETION SUCH THAT EACH CIRCUIT USE AND LOCATION CAN BE QUICKLY AND SIMPLY IDENTIFIED.			A
DB-2		EXISTING DISTRIBUTION BOARD TO REMAIN REMOVE ALL EXISTING CIRCUITS AND ASSOCIATED CABLING THAT BECOMES REDUNDANT DUE TO THE PROPOSED WORKS. UPDATE THE EXISTING LABELLING AND SCHEDULE AT PRACTICAL COMPLETION SUCH THAT EACH CIRCUIT USE AND LOCATION CAN BE QUICKLY AND SIMPLY IDENTIFIED.			A
DB-1A		EXISTING DISTRIBUTION BOARD TO REMAIN REMOVE ALL EXISTING CIRCUITS AND ASSOCIATED CABLING THAT BECOMES REDUNDANT DUE TO THE PROPOSED WORKS. UPDATE THE EXISTING LABELLING AND SCHEDULE AT PRACTICAL COMPLETION SUCH THAT EACH CIRCUIT USE AND LOCATION CAN BE QUICKLY AND SIMPLY IDENTIFIED.			A
MSB		EXISTING MAIN SWITCHBOARD TO REMAIN AS IS.			A
MP		EXISTING ELECTRICITY RETAIL METER PANEL TO REMAIN AS IS			A
DB-1 -P1		PROVIDE CIRCUIT DB-1 -P1 AS A THREE PHASE 40 AMP MCB PROTECTED 4C+E 6MM CIRCUIT SUPPLIED FROM DISTRIBUTION BOARD DB-1			A
DB-1 -P2		PROVIDE CIRCUIT DB-1 -P2 AS A THREE PHASE 40 AMP MCB PROTECTED 4C+E 6MM CIRCUIT SUPPLIED FROM DISTRIBUTION BOARD DB-1			A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3419a - PRINCE OF WALES HOTEL, NUNDAH

C3419a-0002(E).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION E - 28 OCTOBER 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DB-1 -P3		PROVIDE CIRCUIT DB-1 -P3 AS A SINGLE PHASE 20 AMP RCBO PROTECTED 2C+E 2.5MM CIRCUIT SUPPLIED FROM DISTRIBUTION BOARD DB-1			A
FIRE INDICATOR PANEL (FIP)		REPLACE THE EXISTING FIP WITH A CURRENT VERSION OF THE AS1670.1 COMPLIANT WHITE FIRE INDICATOR PANEL.			A
SMOKE DETECTOR		AS1670.1 SURFACE MOUNTED SMOKE DETECTOR WHITE UNLESS NOTED AS BK THEN BLACK			B
RECESSED FIRE ALARM SPEAKER		AS1670.1 RECESSED FIRE ALARM SPEAKER C/W GRILL WHITE UNLESS NOTED AS BK THEN BLACK			B
THERMAL DETECTOR		NOT REQUIRED			B
FIRE ALARM SYSTEM INTERFACE		FIRE ALARM FAILSAFE INTERFACE TO UNLOCK THE DOOR UPON A FIRE ALARM			A