

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3461a - EAGERS MT GRAVATT - 1281 LOGAN ROAD


C3461a-0004(C).xls

DISTRIBUTION BOARD DB-A

REVISION C - 05 FEBRUARY 2026

REV	
FAULT CURRENT:	6KA USING CASCADING
MAIN SWITCH:	250A NON AUTO LOAD BREAK
CHASSIS SIZE:	96 POLE
SUPPLIED FROM:	MSB
CHASSIS RATING:	250A
SUPPLY CABLE:	4C35
PHASES:	3

PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION. EACH CUBICAL MUST BE 700 WIDE. REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3461a - EAGERS MT GRAVATT - 1281 LOGAN ROAD

C3461a-0004(C).xls

DISTRIBUTION BOARD DB-A

REVISION C - 05 FEBRUARY 2026