

# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3540a - HOLLAND PARK HOTEL

C3540a-0004(C).xls

LIGHTING CONTROL SCHEDULE

REVISION C - 02 OCTOBER 2025

MISCELLANEOUS EQUIPMENT				REV	
ITEM	DESCRIPTION			A	
SP1	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
SP2	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
SP3	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
PE CELL	PROGRAMMABLE PE CELL DUS 90CS CONFIRM THE LOCATION ON SITE WITH THE ARCHITECT			A	
TIME CLOCK	PROGRAMMABLE TIME CLOCK ENVISION GATEWAY PDEG LOCATED IN DB-2			A	
CONTROL MODULE 1				A	
TYPE:		DYNALITE DDMC802		A	
DESCRIPTION		8CH MODULAR CONTROLLER		A	
LOCATION		DIN RAIL MOUNTED WITHIN DB-2		A	
BUS:		A		A	
CHANNEL	CONTROL	DESCRIPTION		A	
		LOCATION	CIRCUIT	USE	A
2-1	DGTM202		DB-2 -L1	WL02	A
2-2				WL01	A
2-3	DGTM202			WL02	A
2-4					A
2-5					A
2-6					A
2-7					A
2-8					A
CONTROL MODULE 2				A	
TYPE:		DYNALITE DDMC802		A	
DESCRIPTION		8CH MODULAR CONTROLLER		A	
LOCATION		DIN RAIL MOUNTED WITHIN DB-2		A	
BUS:		A		A	
CHANNEL	CONTROL	DESCRIPTION		A	
		LOCATION	CIRCUIT	USE	A
2-9	DGTM202		DB-2 -L2	PD01 PD11 PD10	A
2-10				PD02	A
2-11	DGTM202			PD09	A
2-12				PD03	A
2-13	DGTM202			PD04	A
2-14					A
2-15					A
2-16					A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075


Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3540a - HOLLAND PARK HOTEL  
LIGHTING CONTROL SCHEDULE  
REVISION C - 02 OCTOBER 2025

C3540a-0004(C).xls

CONTROL MODULE 3					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-2			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
2-19	SWITCHED		DB-2 - L3	RD07	A
2-20	SWITCHED		DB-2 - L3	BUD LIGHTS	A
2-21	SWITCHED		DB-2 - L4	RD06	A
2-22	SWITCHED		DB-2 - L4	RD06	A
2-23	SWITCHED		DB-2 - L5	WL09	A
2-24	SWITCHED		DB-2 - L5	WL08	A
2-25	SWITCHED		DB-2 - L5	WL05	A
2-26	SWITCHED		DB-2 - L5	WL05	A
2-27	SWITCHED		DB-2 - L9	FS01	A
2-28	SWITCHED		DB-2 - L3	FS01	A
2-29					A
2-30					A
CONTROL MODULE 4					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-2			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
2-31	SWITCHED	GAMING	DB-2 - L6	SIGN	A
2-32	SWITCHED	GAMING	DB-2 - L7	SIGN	A
2-33	SWITCHED	GAMING	DB-2 - L8	SIGN	A
2-34	SWITCHED	BISRO	DB-2 - L16	SIGN	B
2-35	SWITCHED	BISRO	DB-2 - L16	SIGN	B
2-36					A
2-37					A
2-38					A
2-39					A
2-40					A
2-41					A
2-42					A
CONTROL MODULE 5					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-2			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-43	DALI DIM		DB-2 - L9	RD04	A
2-44	DALI DIM		DB-2 - L9	SL01	A
2-45	DALI DIM		DB-2 - L9	SL01	A
2-46	DALI DIM		DB-2 - L10	RD01	A
2-47	DALI DIM		DB-2 - L10	RD03	A
2-48	DALI DIM		DB-2 - L10	RD01	A
2-49	DALI DIM		DB-2 - L11	RD01	A
2-50	DALI DIM		DB-2 - L11	RD01	A
2-51	DALI DIM		DB-2 - L11	S5	A
2-52	DALI DIM		DB-2 - L11	RD05	C
2-53	DALI DIM		DB-2 - L11	RD01	A
2-54					A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075


Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3540a - HOLLAND PARK HOTEL  
LIGHTING CONTROL SCHEDULE  
REVISION C - 02 OCTOBER 2025

C3540a-0004(C).xls


<b>CONTROL MODULE 6</b>					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-2			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-56	DALI DIM		DB-2 - L12	RD01	A
2-57	DALI DIM		DB-2 - L12	RD01	A
2-58	DALI DIM		DB-2 - L12	RD03	A
2-59	DALI DIM		DB-2 - L13	SL01	A
2-60	DALI DIM		DB-2 - L13	S2 S3	A
2-61	DALI DIM		DB-2 - L13	RD04	A
2-62					A
2-63	DALI DIM		DB-2 - L13	S18	A
2-64	DALI DIM		DB-2 - L14	S11	A
2-65	DALI DIM		DB-2 - L14	S12	A
2-66	DALI DIM		DB-2 - L14	S10	A
2-67	DALI DIM		DB-2 - L14	S11	A
<b>CONTROL MODULE 7</b>					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-2			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-68	DALI DIM		DB-2 - L14	S10	A
2-69	DALI DIM		DB-2 - L14	S11	A
2-70	DALI DIM		DB-2 - L15	S17	A
2-71	DALI DIM		DB-2 - L15	S8	A
2-72	DALI DIM		DB-2 - L15	S7	A
2-73	DALI DIM		DB-2 - L15	S9	A
2-74	DALI DIM		DB-2 - L15	S9	A
2-75					A
2-76					A
2-77					A
2-78					A
2-79					A
<b>CONTROL MODULE 8</b>					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8CH MODULAR CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-3			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
3-1	DGTM202		DB-3 - L1	PD05	A
3-2				PD06	A
3-3	DGTM202			PD05	A
3-4				PD07	A
3-5					C
3-6					A
3-7					A
3-8					A



**C3540a - HOLLAND PARK HOTEL**  
**LIGHTING CONTROL SCHEDULE**  
**REVISION C - 02 OCTOBER 2025**

**C3540a-0004(C).xls**

CONTROL MODULE 9					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-3			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
3-9	SWITCHED		DB-3 - L2	RD06	A
3-10	SWITCHED		DB-3 - L2	RD06	A
3-11	SWITCHED		DB-3 - L2	RD06	A
3-12	SWITCHED		DB-3 - L3	WL09	A
3-13	SWITCHED		DB-3 - L3	WL09	A
3-14	SWITCHED		DB-3 - L3	BUD LIGHTS	A
3-15	SWITCHED		DB-3 - L3	FS01	A
3-16	SWITCHED		DB-3 - L4	WL04	A
3-17	SWITCHED		DB-3 - L4	WL05	A
3-18	SWITCHED		DB-3 - L4	WL04	A
3-19	SWITCHED		DB-3 - L4	WL07	A
3-20	SWITCHED		DB-3 - L4	WL06	A
CONTROL MODULE 10					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-3			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-21	DALI DIM		DB-3 - L5	RD04	A
3-22	DALI DIM		DB-3 - L5	GL01	A
3-23	DALI DIM		DB-3 - L5	S15	A
3-24	DALI DIM		DB-3 - L5	S14	A
3-25	DALI DIM		DB-3 - L5	S9	A
3-26	DALI DIM		DB-3 - L6	RD01	A
3-27	DALI DIM		DB-3 - L6	RD03	A
3-28	DALI DIM		DB-3 - L6	SL02	A
3-29	DALI DIM		DB-3 - L6	RD02	A
3-30	DALI DIM		DB-3 - L7	SL02	A
3-31	DALI DIM		DB-3 - L7	SL02	A
3-32	DALI DIM		DB-3 - L7	S6	A
CONTROL MODULE 11					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-3			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-33	DALI DIM		DB-3 - L8	RD04	A
3-34	DALI DIM		DB-3 - L8	TL01	A
3-35	DALI DIM		DB-3 - L8	TL01	A
3-36	DALI DIM		DB-3 - L8	TL01	A
3-37	DALI DIM		DB-3 - L9	TL01	A
3-38	DALI DIM		DB-3 - L9	RD01	A
3-39	DALI DIM		DB-3 - L9	RD04	A
3-40	DALI DIM		DB-3 - L9	S17	B
3-41	DALI DIM		DB-3 - L9	RD01	C
3-42					A
3-43					A
3-44					A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3540a - HOLLAND PARK HOTEL

C3540a-0004(C).xls

LIGHTING CONTROL SCHEDULE

REVISION C - 02 OCTOBER 2025

CONTROL MODULE 12					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-3			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-45	DALI DIM		DB-3 - L10	S10	A
3-46	DALI DIM		DB-3 - L10	S9	A
3-47	DALI DIM		DB-3 - L10	S9	A
3-48	DALI DIM		DB-3 - L10	S16	A
3-49	DALI DIM		DB-3 - L10	S13	A
3-50					A
3-51					A
3-52					A
3-53					A
3-54					A
3-55					A
3-56					A
CONTROL MODULE 13					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-3			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
3-57	SWITCHED		DB-3 - L11	SIGN	A
3-58	SWITCHED		DB-3 - L11	SIGN	A
3-59	SWITCHED		DB-3 - L11	SIGN	A
3-60					A
3-61					A
3-62					A
3-63					A
3-64					A
3-65					A
3-66					A
3-67					A
3-20					A