

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3592a - ACGS - CHILDCARE

C3592a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 20 OCTOBER 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	28W 4000K LED	RECESSED 55 DEG BEAM DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM SILVER REFLECTOR	GAMMA ILLUMINATION COBALT 1442-4K	D
L2	22W 4000K LED	RECESSED 55 DEG BEAM DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM SILVER REFLECTOR	GAMMA ILLUMINATION COBALT 1402-4K-22W	D
L3	13W 4000K LED	RECESSED 55 DEG BEAM DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM SILVER REFLECTOR	GAMMA ILLUMINATION COBALT 1402-4K-13W	D
L4	13W 4000K LED	RECESSED 55 DEG BEAM ADJUSTABLE DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM WHITE REFLECTOR	GAMMA ILLUMINATION MYLO 1004-VWFL-4K-13W	A
L5	A SINGLE HORIZONTAL RUN OF LED STRIP LIGHT 4000K WHITE LEDS AT 12MM SPACING WITH REMOTE CONTROL GEAR. MOUNT THE LED STRIP ALONG THE TOP OF THE WINDOW AS PER THE ARCHITECTURAL JOINERY DETAILS THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE SCREW FIX THE ALUMINIUM SUPPORT IN PLACE.			NEON PRODUCTS AUSTRALIA LF-DFB-NW-300-12 + PR-LIN172153-F	B
L6	28W 4000K LED	SURFACE MOUNTED IP65 BUNKER C/W INTEGRAL DRIVER	WHITE TRIM	GAMMA ILLUMINATION MAXI PAT 1359-4K-28W	A
L7	EXISTING HIGH LEVEL FLOOD LIGHT TO BE RETAINED AND RESUPPLIED.				A
L8	EXISTING SOFFIT FLOOD LIGHT TO BE RETAINED AND RESUPPLIED.				A
L9	52W 4000K LED	WALL MOUNTED 65 X 65 BEAM IP65 AREA LIGHT DOWNWARD ORIENTATION C/W INTERNAL DRIVER. CONFIRM THE MOUNTING HEIGHT ON SITE WITH EH ARCHITECT	BLACK	GAMMA ILLUMINATION MOLO 1573-4K-52W1413-3K-22W	A
L10	22W 4000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DRIVER	BLACK	GAMMA ILLUMINATION MERCURY 1290-VWFL 4K-22W	D
L11	22W 4000K LED	RECESSED 75 DEG BEAM DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM WHITE REFLECTOR	GAMMA ILLUMINATION COBALT 1402-WR-4K-22W	D
P1	72W 3500K LED	DECORATIVE PENDANT C/W REMOTE DALI DIMMABLE DRIVER. SUSPEND THE TOP OF THE SHADE 300 BELOW THE CEILING.	YELLOW	LUXBOX KURTAIN STRATUM LARGE KS-L-82-2W-35-DI-G-RD	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3592a - ACGS - CHILDCARE

C3592a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 20 OCTOBER 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
P2	72W 3500K LED	DECORATIVE PENDANT C/W REMOTE DALI DIMMABLE DRIVER. SUSPEND THE TOP OF THE SHADE 300 BELOW THE CEILING.	YELLOW	LUXBOX KURTAIN STRATUM LARGE KS-L-82-2W-35-DI-G-RD	A
P3	72W 3500K LED	DECORATIVE PENDANT C/W REMOTE DALI DIMMABLE DRIVER. SUSPEND THE TOP OF THE SHADE 300 BELOW THE CEILING.	BLUE	LUXBOX KURTAIN STRATUM LARGE KS-L-1W-1R-35-DI-G-RD	A
P4	72W 3500K LED	DECORATIVE PENDANT C/W REMOTE DALI DIMMABLE DRIVER. SUSPEND THE TOP OF THE SHADE 300 BELOW THE CEILING.	GREEN	LUXBOX KURTAIN STRATUM LARGE KS-L-58-1F-35-DI-G-RD	A
P5	72W 3500K LED	DECORATIVE PENDANT C/W REMOTE DALI DIMMABLE DRIVER. SUSPEND THE TOP OF THE SHADE 300 BELOW THE CEILING.	GREEN	LUXBOX KURTAIN STRATUM LARGE KS-L-58-1F-35-DI-G-RD	A
P6	72W 3500K LED	DECORATIVE PENDANT C/W REMOTE DALI DIMMABLE DRIVER. SUSPEND THE TOP OF THE SHADE 300 BELOW THE CEILING.	RED	LUXBOX KURTAIN STRATUM LARGE KS-L-39-90-35-DI-G-RD	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS CLIFE	B
E2	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS CLIFE-BLK	B
EX	LED	EXIT LIGHT THEATRE MASK: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. LITHIUM ION BATTERY	WHITE	CLEVERTRONICS LSBLED	B
EX BK	LED	EXIT LIGHT THEATRE MASK: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. LITHIUM ION BATTERY	BLACK	CLEVERTRONICS LSBLED-BLK	B



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3592a - ACGS - CHILDCARE

C3592a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 20 OCTOBER 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SWITCH PANEL (SP)		MULTIGANG FACEPLATE WITH ONE MECHANISM PER GROUP OF LIGHTS CONTROLLED MOUNTED AT 1000mm AFFL BLACK ENGRAVING	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
PRESENCE DETECTOR SENSOR (PD)		RECESSED PRESENCE DETECTOR SENSOR TO BE WIRED TO OPERATE IN PARALLEL TO ALLOW THE LIGHTS TO TURN ON FOR 15 MINUTES UPON DETECTION OF MOVEMENT WHEN THE SUPPLY HAS MANUALLY BEEN TURNED ON.		CLIPSAL	A
ONE-WAY SWITCH		ONE-WAY SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE UNLESS NOTED AS BK (BLACK)	CLIPSAL C2000 SERIES FACEPLATE	A
TWO-WAY SWITCH		TWO-WAY SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE UNLESS NOTED AS BK (BLACK)	CLIPSAL C2000 SERIES FACEPLATE	A
CONTACTOR (Cx)		HEAVY DUTY SWITCHING CONTACTOR			A
RELAY (Rx)		CONTROL RELAY			A
MANUAL DALI POT		DALI POT C/W INTEGRAL 20 DALI DEVICE POWER SUPPLY C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED IN THE DB-G / DB-1 ESCUTCHEON. FACTOR SET POWER ON RETURN TO LAST LEVEL.	WHITE	SMARTSCAPE DALI RD20	A
SINGLE POWER OUTLET		SINGLE 10 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
POWER OUTLET 20A		SINGLE 20 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
DOUBLE POWER OUTLET		DOUBLE 10 AMP POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
POWER OUTLET USB		DOUBLE POWER OUTLET C/W USB A AND USB C CHARGER, CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND. MOUNT ABOVE BENCH	WHITE	CLIPSAL C2000 SERIES FACEPLATE	B
POWER OUTLET MW		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED WITHIN THE JOINERY AS PER THE ARCHITECTURAL ELEVATION TO SUPPLY THE MICROWAVE.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3592a - ACGS - CHILDCARE

C3592a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 20 OCTOBER 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
POWER OUTLET AD		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED WITHIN THE AUTO DOOR HEAD MULLION.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
CR-A		EXISTING COMMUNICATIONS RACK CR-A TO BE RETAINED AND MODIFIED AS NECESSARY TO ACCOMMODATE THE NEW COMMUNICATIONS OUTLETS. REMOVE ALL REDUNDANT UTP CABLING AND PROVIDE NEW CAT 6 PATCH PANELS TO ACCOMMODATE THE NEW CAT 6 OUTLETS AS REQUIRED. ALL EXISTING COMMUNICATIONS OUTLETS OUTSIDE OF THE WORKS AREA ARE TO BE RETAINED AND RECONNECTED AS REQUIRED TO MAINTAIN THERE OPERATION.			A
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO NEW CAT 6 PATCH PANELS IN CR-A VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BK THEN BLACK	CLIPSAL C2000 SERIES FACEPLATE	B
COMMUNICATIONS OUTLET (RK)		RJ45 CAT-6 COMMUNICATIONS OUTLET MOUNTED IN A VERTICALLY ORIENTATED WALL BOX TO ALLOW THE OUTLET TO BE RECESSED WITHIN THE WALL CAVITY , CABLED BACK TO A CAT 6 PATCH PANELS IN CR-A VIA 4-PAIR CAT-6 UTP CABLE. MOUNT AT 1,400 AFFL. PROVIDE PERMANENT LABELLING FOR EACH OUTLET.	WHITE	CLIPSAL C2000 SERIES FACEPLATE PLUS REPELEC RECWP1WH	A
CCTV OUTLET		MALE RJ45 CAT-6 CCTV PLUS, CABLED BACK TO NEW A CAT 6 PATCH PANEL IN CR-A VIA PURPLE 4-PAIR CAT-6 UTP CABLE. PROVIDE SUFFICIENT LENGTH FOR THE PLUG TO BE CONNECTED DIRECTLY INTO THE CCTV CAMERA PROVIDED BY THE SCHOOL. COORDINATE THE EXACT POSITION ON SITE WITH THE SCHOOL.			A
FUTURE CCTV OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET FOR A FUTURE CCTV CAMERA, CABLED BACK TO NEW CAT 6 PATCH PANELS IN CR-A VIA 4-PAIR PURPLE CAT-6 UTP CABLE. MOUNT ON THE CEILING / FACIA AS INDICATED.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	C
HDMI OUTLET (H)		PROVIDE A FACTORY TERMINATED HDMI CABLE FROM A FACEPLATE BEHIND THE TV TO A LOWER FACE PLATE ADJACENT THE GPO. PROVIDE THE HDMI CABLE WITH A LENGTH OF LESS THAN 5M AS HIGH SPEED HDMI 2.0	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
MSB		EXISTING MAIN SWITCHBOARD TO REMAIN AS IS.			A
DB-A		PROVIDE A NEW DISTRIBUTION BOARD DB-A AS PER THE DB-A SCHEDULE AND NOTES. UTILISE THE EXISTING DISTRIBUTION BOARD SUBMAIN FROM THE MSB TO SUPPLY THE NEW DISTRIBUTION BOARD. THE EXISTING DISTRIBUTION BOARD IS TO BE REMOVED AND ANY REMAINING CIRCUITS ARE TO BE SUPPLIED FROM THE NEW DB-A WITH NEW SWITCHGEAR AND CONTROLS THAT MATCH THE EXISTING IN CAPACITY AND FUNCTION.			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3592a - ACGS - CHILDCARE

C3592a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 20 OCTOBER 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
FIRE INDICATOR PANEL (FIP)		FLUSH MOUNTED AS1670.1 FIRE INDICATOR PANEL CONTAINING A THE FIRE DETECTION CONTROL AND INDICATING EQUIPMENT AND THE EMERGENCY WARNING CONTROL AND INDICATING EQUIPMENT. NETWORK THE NEW FIP INTO THE SCHOOLS EXISTING BRIGADE MONITORED FIRE ALARM SYSTEM.			A
SMOKE DETECTOR		SURFACE MOUNTED ADDRESSABLE AS1670.1 COMPLIANT SMOKE DETECTOR WHITE UNLESS NOTED AS BK (BLACK). ENSURE ALL SMOKE DETECTORS ARE PROVIDED AS AS 7240.7 POINT DETECTORS WITH A PERFORMANCE OF 6 TO 12 % OBS/M SET AT 7.8 %			A
CONCEALED SPACE SMOKE DETECTOR		ADDRESSABLE AS1670 COMPLIANT CONCEALED SPACE SMOKE DETECTOR C/W REMOTE INDICATOR AND REMOTE ACCESS BRACKET IF REQUIRED ENSURE ALL SMOKE DETECTORS ARE PROVIDED AS AS 7240.7 POINT DETECTORS WITH A PERFORMANCE OF 6 TO 12 % OBS/M SET AT 7.8 %			A
THERMAL DETECTOR		SURFACE MOUNTED ADDRESSABLE AS1670 COMPLIANT THERMAL DETECTOR WHITE UNLESS NOTED AS BK (BLACK)			A
FIRE ALARM SYSTEM SPEAKER		RECESSED AS1670.1 COMPLIANT RECESSED ALERT AND EVACUATION SPEAKER C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE.	WHITE UNLESS NOTED AS BK (BLACK)	TYPE TO MATCH THE PA BELL SPEAKER IN APPEARANCE	A
FIRE ALARM SYSTEM ACCESS CONTROL INTERFACE		INTERFACE THE FIRE ALARM SYSTEM TO THE SECURITY SYSTEM SUCH THAT UPON ALARM THE DOOR UNLOCKS.			A
FIRE ALARM SYSTEM STROBE		PROVIDE A WEATHERPROOF AS1670.1 ALARM STROBE AT HIGH LEVEL.			A
SECURITY EQUIPMENT		EXISTING SECURITY EQUIPMENT TO BE UPGRADES AS NECESSARY TO ACCOMMODATE THE ADDITIONS AND CHANGES. THE EXISTING POWER OUTLETS AND NETWORK CONNECTION IS TO BE RETAINED.			A
AD		INTERFACE THE ACCESS CONTROL SYSTEM INTO THE AUTO DOOR.			A
INTRUDER DETECTION SENSOR		DUAL-TECHNOLOGY MOVEMENT DETECTORS WALL MOUNTED AS PER THE MANUFACTURER'S SPECIFICATION. CONNECT TO THE LOCAL SECURITY EQUIPMENT WITH ONE DETECTOR PER ZONE. WHITE UNLESS NOTED AS BK THEN BLACK			B
PIEZO ALARM		WALL MOUNTED SECURITY SYSTEM INTRUDER BLACK			B
SECURITY STROBE SIREN		REPLACE THE EXISTING EXTERNAL SECURITY STROBE SIREN WITH A NEW STROBE SIREN			A
ACCESS CONTROL DOOR RELEASE PUSH BUTTON (PB)		PROVIDE THE DOOR WITH A FAIL SAFE PUSH BUTTON MOUNTED AT 1000 AFFL TO UNLOCK THE DOOR. PROVIDE BLACK ENGRAVING "IN AN EMERGENCY PRESS TO UNLOCK. CONNECT THE "PUSH BUTTON TO THE ACCESS CONTROL SYSTEM TO UNLOCK THE ASSOCIATED MAGNETIC HOLDER.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3592a - ACGS - CHILDCARE

C3592a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 20 OCTOBER 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/links.html					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
ACCESS CONTROL DOOR ELECTRIC STRIKE 1 (ES1)		PROVIDE THE DOOR WITH ACCESS CONTROL UTILISING A FLUSH MOUNTED ELECTRIC DOOR STRIKE PLATE. CONNECT THE ELECTRIC STRIKE TO THE ACCESS CONTROL SYSTEM. PROVIDE CONCEALED DOOR READER MODULES & AUXILIARY POWER SUPPLIES AS REQUIRED. EACH ELECTRIC STRIKE DOOR IS TO BE PROVIDED WITH DOOR STATUS REPORTING (DOOR OPEN / DOOR CLOSED) REED SWITCH. ALL CABLING AND CONDUITS ASSOCIATED WITH THE ELECTRIC STRIKE IS TO BE CONCEALED.			A
ACCESS CONTROL DOOR ELECTRIC STRIKE 2 (ES2)		UTILISE THE EXISTING FLUSH MOUNTED ACCESS CONTROL ELECTRIC DOOR STRIKE PLATE. CONNECT THE ELECTRIC STRIKE TO THE ACCESS CONTROL SYSTEM. PROVIDE CONCEALED DOOR READER MODULES & AUXILIARY POWER SUPPLIES AS REQUIRED. PROVIDE THE ELECTRIC STRIKE DOOR WITH A NEW DOOR STATUS REPORTING (DOOR OPEN / DOOR CLOSED) REED SWITCH. ALL CABLING AND CONDUITS ASSOCIATED WITH THE ELECTRIC STRIKE IS TO BE CONCEALED.			A
ACCESS CONTROL DOOR ELECTRIC STRIKE 3 (ES3)		EXISTING EXTERNAL GATE ACCESS CONTROL ELECTRIC DOOR STRIKE PLATE TO BE RETAINED AS IS.			A
ACCESS CONTROL DOOR CARD READER (CR)		WALL-MOUNTED 1000AFFL VANDAL-RESISTANT ACCESS CONTROL SYSTEM HEAVY-DUTY PROXIMITY CARD READER PROVIDE DOOR READERS AND POWER SUPPLIES AS REQUIRED ALL EXISTING CARD READERS ARE TO BE REPLACED UNLESS NOTED OTHERWISE. ALL CABLING AND CONDUITS ASSOCIATED WITH THE CARD READER IS TO BE CONCEALED.			A
VIDEO INTERCOM CALL STATION (ICS)		AS PART OF THE SECURITY SCOPE, PROVIDE A FLUSH WEATHERPROOF WALL MOUNTED STAINLESS STEEL COLOUR IP VIDEO CALL STATION INTERFACED TO THE SCHOOL IT NETWORK TO GENERATE A TONE ON PREDEFINED SMART PHONES AND COMPUTERS. PROVIDE THE ABILITY FOR THE USER OF THE ASSOCIATED SMART PHONE AND COMPUTER TO TALK / SIGHT TO THE GUEST AT THE ICS AND UNLOCK THE AUTO DOOR. PROVIDE THE SYSTEM WITH THE ABILITY TO DISABLE THE INTERCOM VIA A PREDEFINED DATE / TIME SCHEDULE. SUBMIT DETAILS OF THE PROPOSED INTERCOM SYSTEM FOR APPROVAL.			A
PUBLIC ADDRESS RECESSED SPEAKER		FLUSH RECESSED PA SYSTEM CONE SPEAKER C/W WHITE GRILL.			A
PUBLIC ADDRESS HORN SPEAKER		WALL MOUNTED WEATHERPROOF PUBLIC ADDRESS HORN SPEAKER.			A
EMERGENCY CONTROL PANEL (ECP)		RELOCATE THE EXISTING PA SYSTEM EMERGENCY CONTROL PANEL.			A