



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3734a - COOMERA TAVERN
DISTRIBUTION BOARD DB-T2B
REVISION A - 03 JUNE 2026

C3734a-0006(A).xls

							REV
EXISTING DISTRIBUTION BOARD TO BE PROVIDED WITH NEW SWITCHGEAR TO ACCOMMODATE THE FOLLOWING NEW CIRCUITS. REPLACE THE TWO THREE PHASE MCBS AND THE ASSOCIATED 3 POLE RCD UNITS WITH 3 POLE RCBOs. ANY EXISTING CIRCUITS AND ASSOCIATED SWITCHGEAR THAT BECOMES REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED. UPDATE THE SCHEDULE AT PRACTICAL COMPLETION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5		TV	A
L1	1	20	RCBO	2.5		LIGHTING	A
L2	1	20	RCBO	2.5		LIGHTING	A
L3	1	20	RCBO	2.5		LIGHTING	A