

# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S1	14.4W/M 2700K LED	LED STRIP IN A RECTANGULAR CONFIGURATION (FOUR SIDES) WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER BEHIND THE TV AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED R2334 2700K PLUS R2380 ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	B
S2	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE BAR FRONT FEATURE AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S3	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE REAR BAR JOINERY AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S4	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON TOP OF THE SUSPENDED SHELF AS PER THE ARCHITECTIAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
S5	14.4W/M 2700K LED	THREE PARRALL RUNS OF LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON UNDERSIDE OF THE GAMING BAR BULKHEAD AS PER THE ARCHITECTIAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE EXTRUSION	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	B
S6	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE REAR BAR JOINERY AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE


REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S7	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER BEHIND THE MIRROR AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
S8	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE CEILING AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK EXTRUSION	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	B
S9	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE GAMING ROOM CURTAIN PELMET AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
S10	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RISING VERTICALLY FROM THE FLOOR AND HORIZONALLY ACROSS THE DOORWAY IN THE GAMING ENTRY PORTAL Y AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	B
PD01	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 1000 LUMENS +/- 10%	720 DIA X 220 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	WHITE	FAT SHACK VINTAGE HAMBLIN FABRIC PENDANT	B
PD02	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	1000 DIA X 650 H DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	RATTAN	THE STYLING REPUBLIC BETTY	B
PD03	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	620 DIA X 380 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	NATURAL RATTAN	LIGHTHOUSE LANE PORTSEA PENDANT LIGHT	B

C3743a-0002(D).xls

Pages inc. any attach. 2 of 8



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PD04	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 G45 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT C/W 2000 BRAIDED TEXTILE CABLE. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	LARGE CLEAR SHADE	FAT SHACK CHAPMAN GLASS NORD PENDANT P1189-CLR-LRG	D
PD05	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 750 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	600 DIA X 600 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	GOLD FINISH CHAIN BRONZE FRAME	ABOUT SPACE ID 128010 TYPE A J23 26-00006380	B
PD06	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 750 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	1010 DIA X 580 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	GOLD FINISH CHAIN BRONZE FRAME	ABOUT SPACE ID 128010 TYPE B J23 26-00006380	B
PD07	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 G45 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	250 DIA DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	GOLD	FAT SHACK ORBITAL GLASS PENDANT SKU: P420- OPL-GLD	D
PD08	TRAILING EDGE DIMMABLE 240 VOLT 2200K E14 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	150 DIA X 140 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK	FAT SHACK STELLER REEDED GLASS P1138-AMB	D
PD09	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 750 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	750 DIA X 250 H DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	RATTAN	TEMPLE & WEBSTER ZAYN RATTAN PENDANT	B
PD10	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	770 DIA X 490 HIGH DECORATIVE PENDANT. CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	ROPE	TEMPLE & WBSTER EVERETT IRON ROPE 3 LAMP PENDANT	B
PD11	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 750 LUMENS +/- 10%	ALLOW TO INSTALL ALLOW A PC SUM FOR THE SUPPLY OF EACH PD11 FITTING	TBA	ALLOW A PC SUM OF \$1,000.00 PLUS GST FOR THE SUPPLY OF EACH PD11 FITTING	C
WL01	INTEGRAL 8W 2700K LED	DECORATIVE 135 DIA X 80 DEEP WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	AMBER	FAT SHACK SKU W1179-AMB-SAW	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL02	TRAILING EDGE DIMMABLE 240 VOLT 2200K E14 CANDLE LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 250 HIGH X 150 DEEP WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	WHITE SPECKLE	TEMPLE & WEBSTER CAPRI TERRACOTTA WALL SCONCE	A
WL03	TRAILING EDGE DIMMABLE 240 VOLT 2200K E14 CANDLE LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 250 HIGH X 150 DEEP WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	TERRACOTTA	TEMPLE & WEBSTER CAPRI TERRACOTTA WALL SCONCE	A
WL04	TRAILING EDGE DIMMABLE 240 VOLT 2200K G9 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 350 DIA X 150 PROJECTION WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	ANTIQUE GOLD	ZEST LIGHTING MIKUMI PLEATED ANTIQUE GOLD BASE ROUND WALL LIGHT	B
WL05	TRAILING EDGE DIMMABLE 240 VOLT 2200K B22 A60 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 350 DIA X 270MM H LARGE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	WHITE SHADE WHITE SCONCE	FAT SHACK VINTAGE W819-WHT-LRG-WHT CONE ADJUSTABLE SWIVEL ARM	B
WL06	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 A60 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 320 DIA X 310 WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	GRAPHITE	FATSHACK VINTAGE W119-GPH	B
WL07	NO LONGER REQUIRED				B
WL08	NO LONGER REQUIRED				B
WL09	NO LONGER REQUIRED				B
WL10	TRAILING EDGE DIMMABLE 240 VOLT 2200K GU10 LED 250 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE 110 DEEP X 100 L X 90 HIGH WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	BLACK	ABOUT SPACE SILFA	B
WL11	INTEGRAL 15W 3000K LED	DECORATIVE 200 DIA X 70 DEEP WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	WHITE	ABOUT SPACE KLIPS 200 DIA	B
WL12	INTEGRAL 6W 3000K LED	DECORATIVE 30 DEEP X 110 HIGH WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	BLACK	ABOUT SPACE JBO WALL LIGHT	B



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WLE	EXISTING WALL MOUNTED LIGHT FITTING TO BE RETAINED AND RESUPPLIED AS INDICATED. WITHIN ONE WEEK OF BEING AWARDED THE CONTRACT CONFIRM THE EXISTING LAMP TYPE AND CONTROL TYPE AS TRAILING EDGE, LEADING EDGE, DSI, 0-10, DALI OR SWITCHED.				A
RD01	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH-15W-WW-DALI	A
RD02	15W 3000K LED	75 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1077-WH-15W-WW-DALI	A
RD03	15W 3000K LED	RECESSED RECTANGULAR DOUBLE HEAD ADJUSTABLE DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1067-WH-15W-WW-DALI	A
RD04	18W 3000K LED	150 DIA IP54 RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1093-18-WH-SIL-TRI DALI	B
RD10	NO LONGER REQUIRED				C
RD11	18W 3000K LED	150 DIA IP54 RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1093-18-WH-SIL-TRI DALI	A
RDE	EXISTING LIGHT FITTING TO BE RETAINED AND RESUPPLIED AS INDICATED. WITHIN ONE WEEK OF BEING AWARDED THE CONTRACT CONFIRM THE EXISTING LAMP TYPE AND CONTROL TYPE AS TRAILING EDGE, LEADING EDGE, DSI, 0-10, DALI OR SWITCHED.				A
SL01	15W 3000K LED	SURFACE MOUNTED 62 DIA 172 HIGH CAN DOWNLIGHT C/W 40DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	LUMEN 8 SOLIS SOROSU15930TR WHITE 15W 40DEG	B
SL02	40W 3000K LED	SURFACE MOUNTED 72 DIA 210 HIGH CAN DOWNLIGHT C/W 45DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	LUMEN 8 SOROSU40930ND WHITE 40W 40DEG	B
SL03	15W 3000K LED	SURFACE MOUNTED 62 DIA 172 HIGH CAN DOWNLIGHT C/W 40DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	LUMEN 8 SOLIS SOROSU15930TR WHITE 15W 40DEG	B
SL04	40W 3000K LED	SURFACE MOUNTED 72 DIA 210 HIGH CAN DOWNLIGHT C/W 45DEG BEAM REMOTE DALI DIMMABLE DRIVER AND A CUSTOM ANGLED TIMBER MOUNTING BLOCK TO ALLOW THE FITTING TO MOUNT VERTICALLY. THE MOUNTING BLOCK IS TO BE PAINTED TO MATCH THE FITTING COLOUR AND BE AS SMALL AS PRACTICAL.	WHITE	LUMEN 8 SOROSU40930ND WHITE 40W 40DEG	B

C3743a-0002(D).xls

Pages inc. any attach. 5 of 8



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL


C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SLE	EXISTING SURFACE MOUNTED LIGHT FITTING TO BE RETAINED AND RESUPPLIED AS INDICATED. WITHIN ONE WEEK OF BEING AWARDED THE CONTRACT CONFIRM THE EXISTING LAMP TYPE AND CONTROL TYPE AS TRAILING EDGE, LEADING EDGE, DSI, 0-10, DALI OR SWITCHED.				A
GL01	8W 3000K LED	GARDEN STAKE FITTING C/W REMOTE DALI DIMMABLE DRIVER MOUNT THE FITTING IN THE GARDEN AS PER THE ARCHITECTURAL DETAIL IT IS ACCEPTABLE TO SUPPLY MULTIPLE UP2 FITTINGS ON THE SAME CHANNEL FROM A SINGLE SUITABLY SIZED DRIVER / POWER SUPPLY	BLACK	GAMMA ILLUMINATION RULLO 1373- FL-8W- 3K	A
BL01	2200K LED	TREE BUD LIGHTS. ALLOW A PC SUM FOR THE SUPPLY AND INSTALLATION OF EACH BL01 FITTING.	WHITE	ALLOW A PC SUM OF \$10,000.00 PLUS GST FOR THE SUPPLY OF EACH BD01 FITTING	A
G1	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED IN THE GAMING CEILING FEATURE COFFER ABOVE THE PLANTER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2334 2700K PLUS R2380 ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	B
R1	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED IN THE GAMING CEILING FEATURE COFFER ABOVE THE PLANTER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2334 2700K PLUS R2380 ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	B
FE	EXISTING CEILING FAN AND ASSOCIATED CONTROLLER TO BE RETAINED.				A
F02	REPLACE THE EXISTING CEILING FAN AND CONTROLLER WITH A NEW 1320 DIA COASTAL GRADE FAN AND WALL MOUNTED CONTROLLER UTILISE THE EXISTING CIRCUIT		WHITE	VENTAIR SPIN1304WH	C
FS01	1W LED AT 500 CENTRES	REPLACE THE EXISTING FESTOON LIGHT WITH NEW 24V DC IP65 FESTOON LIGHTING TO BE FIXED TO A 316 STAINLESS STEEL WIRE SUPPORT SYSTEM. SUPPLY THE NEW FESTOON LIGHTS VIA REMOTE DALI DIMMABLE DRIVERS IN A CONCEALED ACCESSIBLE POSITIONS NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE LENGTH AND POSITION ON SITE CONNECT THE NEW FESTOON LIGHTS WITH A NEW SUPPLY TO THE NEW LIGHTING CONTROL SYSTEM	BLACK CABLE AND FIXINGS 316 STAINLESS STEEL SUPPORT AND FIXINGS	FIRE FLY FFC-LS-50-24VE27-BK	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
FDE		EXISTING FLOOD LIGHT TO BE RETAINED AND RESUPPLIED AS INDICATED. WITHIN ONE WEEK OF BEING AWARDED THE CONTRACT CONFIRM THE EXISTING LAMP TYPE AND CONTROL TYPE AS TRAILING EDGE, LEADING EDGE, DSI, 0-10, DALI OR SWITCHED.			A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	A
E2		EXISTING EMERGENCY LIGHT TO BE RETAINED			A
EX E3		EXISTING EMERGENCY EXIT LIGHT TO BE RETAINED			A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LUBPRO-SM	A
EX BK	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	BLACK	CLEVERTRONICS LUBPRO-SM-BLK	A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
LIGHTING CONTROL SWITCH PANEL 1 (SP1)		EXISTING DYNALITE ANTUMBRA DISPLAY TO BE CONNECTED TO THE NEW LIGHTING CONTROL SYSTEM. REMOVE THE EXISTING MANUAL LIGHTING CONTROLS THAT BECOME REDUNDANT.			A
LIGHTING CONTROL SWITCH PANEL 2 (SP2)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. REMOVE THE EXISTING MANUAL LIGHTING CONTROLS THAT BECOME REDUNDANT.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
LIGHTING CONTROL SWITCH PANEL 3 (SP3)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. REMOVE THE EXISTING MANUAL LIGHTING CONTROLS THAT BECOME REDUNDANT.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
AUTO DOOR SINGLE POWER OUTLET (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A

C3743a-0002(D).xls

Pages inc. any attach. 7 of 8



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3743a - COOLUM BEACH HOTEL

C3743a-0002(D).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 29 MAY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
AUTO DOOR SINGLE POWER OUTLET (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION LOCATED CONCEALED WITHIN THE AUTO DOOR HEAD MULLION RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE CONNECTION ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
DB-1		EXISTING DISTRIBUTION BOARD DB-1 LOCATED ON THE MEZZANINE LEVEL TO BE PROVIDED WITH NEW SWITCHGEAR TO ACCOMMODATE THE NEW CIRCUITS AS NOTED IN THE DISTRIBUTION BOARD DB-1 SCHEDULE. ANY EXISTING CIRCUITS THAT BECOME REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED. PROVIDE DB-1 WITH A WALL MOUNTED DIN RAIL CUBICAL TO ACCOMMODATE THE NEW DB-1 LIGHTING CONTROL GEAR. ENSURE THE CUBICAL CONTAINS AT LEAST ONE SPARE 600 WIDE HORIZONTAL DIN RAIL IN ADDITION TO THAT NECESSARY TO ACCOMMODATE THE INITIAL DYNALITE CONTROL EQUIPMENT.			A
DB-2		EXISTING DISTRIBUTION BOARD DB-2 LOCATED ON THE MEZZANINE LEVEL TO BE USED AS THE GAMING DB BY THE GAMING ELECTRICIAN. ANY EXISTING CIRCUITS THAT BECOME REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED. RELOCATE ANY EXISTING CIRCUITS THAT REMAIN TO DB-1.			A
DB-3		EXISTING DISTRIBUTION BOARD DB-3 TO BE PROVIDED WITH NEW SWITCHGEAR TO ACCOMMODATE THE NEW CIRCUITS AS NOTED IN THE DISTRIBUTION BOARD DB-3 SCHEDULE. ANY EXISTING CIRCUITS THAT BECOME REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED. PROVIDE DB-3 WITH A WALL MOUNTED DIN RAIL CUBICAL TO ACCOMMODATE THE NEW DB-3 LIGHTING CONTROL GEAR. ENSURE THE CUBICAL CONTAINS AT LEAST ONE SPARE 600 WIDE HORIZONTAL DIN RAIL IN ADDITION TO THAT NECESSARY TO ACCOMMODATE THE INITIAL DYNALITE CONTROL EQUIPMENT.			A
DB-4		EXISTING DISTRIBUTION BOARD DB-4 TO BE PROVIDED WITH NEW SWITCHGEAR TO ACCOMMODATE THE NEW CIRCUITS AS NOTED IN THE DISTRIBUTION BOARD DB-4 SCHEDULE. ANY EXISTING CIRCUITS THAT BECOME REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED. PROVIDE DB-4 WITH A WALL MOUNTED DIN RAIL CUBICAL TO ACCOMMODATE THE NEW DB-4 LIGHTING CONTROL GEAR. ENSURE THE CUBICAL CONTAINS AT LEAST ONE SPARE 600 WIDE HORIZONTAL DIN RAIL IN ADDITION TO THAT NECESSARY TO ACCOMMODATE THE INITIAL DYNALITE CONTROL EQUIPMENT.			A
MSB		EXISTING HOTEL MAIN SWITCHBOARD LOCATED ON THE MEZZANINE LEVEL TO REMAIN.			A