



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3747a - MELBOURNE HOTEL, BUNDABERG

C3747a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 12 MAY 2026

MISCELLANEOUS EQUIPMENT				REV	
ITEM	DESCRIPTION			A	
SP1	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
SP2	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
SP3	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
SP4	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM			A	
PE CELL	PROGRAMMABLE PE CELL DUS 90CS CONFIRM THE LOCATION ON SITE WITH THE ARCHITECT			A	
TIME CLOCK	PROGRAMMABLE TIME CLOCK ENVISION GATEWAY PDEG LOCATED IN DB-A			A	
CONTROL MODULE 1				A	
TYPE:		DYNALITE DDMC802		A	
DESCRIPTION		8CH MODULAR CONTROLLER		A	
LOCATION		DIN RAIL MOUNTED WITHIN DB-L		A	
BUS:		A		A	
CHANNEL	CONTROL	DESCRIPTION		A	
		LOCATION	CIRCUIT	USE	
1	DGTM202		DB-L -L1	PD01	A
2				WL01	A
3	DGTM202			WL03	A
4					A
5					A
6					A
7					A
8					A
CONTROL MODULE 2				A	
TYPE:		DYNALITE DDMC802		A	
DESCRIPTION		8CH MODULAR CONTROLLER		A	
LOCATION		DIN RAIL MOUNTED WITHIN DB-L		A	
BUS:		A		A	
CHANNEL	CONTROL	DESCRIPTION		A	
		LOCATION	CIRCUIT	USE	
9	DGTM202		DB-L -L2	PD02	A
10				PD03	A
11	DGTM202			WL01	A
12				WL04	A
13	DGTM202			WL02	A
14					A
15	DGTM202			WL05	A
16					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3747a - MELBOURNE HOTEL, BUNDABERG

C3747a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 12 MAY 2026

CONTROL MODULE 3					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12CH 20 A FEEDTHROUGH RELAY CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-L			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
17	SWITCHED	ROOF	DB-L -L3	SIGNAGE	A
18	SWITCHED	EXTERNAL	DB-L -L4	SIGNAGE	A
19	SWITCHED	EXTERNAL	DB-L -L4	SIGNAGE	A
20	SWITCHED	EXTERNAL	DB-L -L5	SIGNAGE	A
21	SWITCHED	EXTERNAL	DB-L -L5	UL01 UL02	A
22	SWITCHED	EXTERNAL	DB-L -L4	SL01	A
23					A
24					A
25					A
26					A
27					A
28					A
CONTROL MODULE 4					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-L			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
29	DALI DIM		DB-L- L6	WL06	A
30	DALI DIM		DB-L- L6	S1	A
31	DALI DIM		DB-L- L6	S5	A
32	DALI DIM		DB-L- L6	S8	A
33	DALI DIM		DB-L- L6	S5	A
34	DALI DIM		DB-L- L6	S1	A
35	DALI DIM		DB-L- L6	S1	A
36					A
37					A
38					A
39					A
40					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3747a - MELBOURNE HOTEL, BUNDABERG

C3747a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 12 MAY 2026

CONTROL MODULE 5					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-L			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
41	DALI DIM		DB-L- L7	RD05	A
42	DALI DIM		DB-L- L7	RD04	A
43	DALI DIM		DB-L- L7	RD02	A
44	DALI DIM		DB-L- L7	TL01	A
45	DALI DIM		DB-L- L8	RD04	B
46	DALI DIM		DB-L- L8	RD02	A
47	DALI DIM		DB-L- L8	RD03	A
48	DALI DIM		DB-L- L8	TL01	A
49	DALI DIM		DB-L- L8	RD02	A
50	DALI DIM		DB-L- L8	RD02	A
51					A
52					A
CONTROL MODULE 6					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-L			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
53	DALI DIM		DB-L- L9	S8	A
54	DALI DIM		DB-L- L9	GL01	A
55	DALI DIM		DB-L- L9	S1	A
56	DALI DIM		DB-L- L9	S7	A
57	DALI DIM		DB-L- L9	S8	A
58	DALI DIM		DB-L- L9	S1	A
59	DALI DIM		DB-L- L9	S6	A
60	DALI DIM		DB-L- L10	RD01	A
61	DALI DIM		DB-L- L10	RD03	A
62	DALI DIM		DB-L- L10	RD01	A
63	DALI DIM		DB-L- L10	RD01	A
64	DALI DIM		DB-L- L10	RD05	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3747a - MELBOURNE HOTEL, BUNDABERG

C3747a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 12 MAY 2026

CONTROL MODULE 7					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-L			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
65	DALI DIM		DB-L- L11	S4	A
66	DALI DIM		DB-L- L11	S3	A
67	DALI DIM		DB-L- L11	S2	A
68	DALI DIM		DB-L- L11	RD01	A
69	DALI DIM		DB-L- L12	RD02	B
70	DALI DIM		DB-L- L12	SL02	A
71	DALI DIM		DB-L- L12	RD02	A
72	DALI DIM		DB-L- L12	RD02	A
73	DALI DIM		DB-L- L13	RD05	A
74	DALI DIM		DB-L- L13	RD02	A
75	DALI DIM		DB-L- L13	RD02	A
76					A
CONTROL MODULE 8					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-L			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
77	DALI DIM		DB-L- L14	RD01	A
78	DALI DIM		DB-L- L14	RD02 & RD04	B
79					A
80					A
81					A
82					A
83					A
84					A
85					A
86					A
87					A
88					A