



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3857a - ACGS - CAMPBELL CENTRE REFURBISHMENT

C3857a-0002(T1).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION T1 - 06 OCTOBER 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN THE CEILING TBAR	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W	T1
L2	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	T1
L3	36W LED 4000K	1200 LONG SURFACE MOUNTED IP65 DIFFUSED BATTEN C/W INTEGRAL ELECTRONIC CONTROL GEAR	LIGHT GREY	GAMMA STORM 1558-CCT-36W	T1
L4	14.4W/M 4000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE JOINERY RECESS AS PER THE ARCHITECTURAL DETAIL TO ILLUMINATE DOWNWARDS. PROVIDE THE STRIP WITH A REMOTE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 4000 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY	T1
L5	13W 4000K LED	RECESSED 41 DEG BEAM DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	GAMMA ILLUMINATION COBALT 1402-4K-13W	T1
L6	22W 4000K LED	RECESSED 41 DEG BEAM DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	GAMMA ILLUMINATION COBALT 1402-4K-22W	T1
L7	28W 4000K LED	RECESSED 41 DEG BEAM DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	GAMMA ILLUMINATION COBALT 1442-4K-28W	T1
L8	EXISTING HIGH BAY LIGHTS TO BE RECONNECTED AS INDICATED				T1
L9	23W 4000K LED	REPLACE THE EXISTING POLE AND FITTING WITH A NEW AREA LIGHT MOUNTED ON A 4m HIGH ROUND BLACK POLE PROVIDE A SHOP DRAWING OF THE POLE AND FOOTING FOR APPROVAL AND CERTIFICATION BY A STRUCTURAL ENGINEER OF THE POLE AND FOOTING.	BLACK FITTING AND POLE	PIERLITE DISANO STELVIO MINI 3278 Fx T3 16 Leds, 530 mA	T1
L10	23W 4000K LED	WALL MOUNTED AREA LIGHT	BLACK FITTING	PIERLITE DISANO STELVIO MINI 3278 Fx T3 16 Leds, 530 mA	T1

C3857a-0002(T1).xls

Pages inc. any attach. 1 of 6



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3857a - ACGS - CAMPBELL CENTRE REFURBISHMENT

C3857a-0002(T1).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION T1 - 06 OCTOBER 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L11	23W 4000K LED	REPLACE THE EXISTING WALL MOUNTED AREA LIGHT	BLACK FITTING	PIERLITE DISANO STELVIO MINI 3278 Fx T3 16 Leds, 530 mA	T1
L12	52W 4000K LED	WALL MOUNTED AREA LIGHT	BLACK FITTING	PIERLITE DISANO STELVIO 330370-00	T1
L13	EXISTING LED BUNKER LIGHT TO BE RETAINED.				T1
L14	NEW LED BUNKER LIGHT TO MATCH THE EXISTING L13 FITTING.				T1
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	T1
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0- D6.3- C90-E3.2.	WHITE	CLEVERTRONICS LSBLED	T1
EMERGENCY PACK		LIGHT FITTINGS THAT ARE DESIGNATED AS BEING PROVIDED WITH AN EMERGENCY PACK ARE TO BE PROVIDED WITH AN INTEGRAL AS2293 EMERGENCY PACK. THE FITTINGS ARE TO BE NON MAINTAINED WITH ALL LAMPS SWITCHED AS PER THE LIGHTING CONTROL FOR THAT SPACE UNLESS NOTED OTHERWISE. REFER TO THE NOTES FOR FURTHER DETAILS OF THE CONFIGURATION AND SWITCHING OF EMERGENCY LIGHTS.			T1
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL ICONIC SERIES	T1
TWO-WAY LIGHT SWITCH		TWO-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL ICONIC SERIES	T1
SWITCH PANEL 1 SP1		MULTIPLE MULTI GANG LIGHT SWITCH PANELS CONFIGURED AS PER THE SP1 SCHEMATIC. MOUNT AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL ICONIC SERIES	T1
PROXIMITY DETECTOR SWITCH (PD)		ADJUSTABLE FLUSH RECESSED 360 DEGREE PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	WHITE	CLIPSAL	T1



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3857a - ACGS - CAMPBELL CENTRE REFURBISHMENT

C3857a-0002(T1).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION T1 - 06 OCTOBER 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND. MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL ICONIC SERIES	T1
SUSPENDED SINGLE POWER OUTLET		SUSPENDED SINGLE 10 POWER OUTLET. PROVIDE A 3MM STAINLESS STEEL WIRE SUPPORT AND CONFIRM THE SUSPENSION HEIGHT WITH THE SCHOOL ON SITE.	GREY	CLIPSAL SS15-GY	T1
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND. MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL ICONIC SERIES	T1
DOUBLE POWER OUTLET (USB)		DOUBLE POWER OUTLET C/W USB CHARGER AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL ICONIC SERIES PLUS 40E2USBACM-VW	T1
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	-	CLIPSAL WSCF227F	T1
IP56 WEATHERPROOF POWER OUTLET (WP)		IP56 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	-	CLIPSAL "56 SERIES"	T1
BLACK FITTING (BK)		FITTING / OUTLET NOTED AS BK IS TO BE PROVIDED AS BLACK IN COLOUR OR PAINTED BLACK.	BLACK	-	T1
SPECIAL PURPOSE POWER OUTLET		SPECIAL PURPOSE POWER OUTLET. MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. SIZE AND TYPE AS NOTED	-	-	T1
HAND DRYER CONNECTION (HD)		THE ELECTRICAL SUB CONTRACTOR IS TO TAKE POSSESSION OF THE HAND DRYER AND INSTALL IT WITH 20A ISOLATING SWITCH WALL MOUNTED CONNECTED TO THE HAND DRYER UNIT AS PER DETAIL. PROVIDE CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND	WHITE	CLIPSAL ICONIC SERIES	T1
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	T1
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. "RSD" DENOTES ROLLER SHUTTER DOOR SUPPLY - COORDINATE LOCATION ONSITE WITH MOTOR.	-	CLIPSAL WHT35	T1
MOTORISED LOUVER (ML)		EXISTING MOTORISED LOUVER AND ASSOCIATED CONTROLS TO BE RETAINED			T1
CEILING FAN (FL1)		EXISTING CEILING FAN AND ASSOCIATED CONTROLS TO BE RETAINED			T1

C3857a-0002(T1).xls

Pages inc. any attach. 3 of 6



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3857a - ACGS - CAMPBELL CENTRE REFURBISHMENT

C3857a-0002(T1).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION T1 - 06 OCTOBER 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
MSB-P		EXISTING MAIN SWITCHBOARD TO BE MODIFIED AS PER THE POWER SCHEMATIC AND ASSOCIATED NOTES.			T1
MDB-C		EXISTING DISTRIBUTION BOARD TO REMAIN AS IS.			T1
DB-C		EXISTING DISTRIBUTION BOARD DB-C TO BE MODIFIED AS NECESSARY TO ACCOMMODATE THE CHANGES AND ADDITIONAL AS PER THE NOTES AND THE DISTRIBUTION BOARD DB-C SCHEDULE.			T1
DB-D		EXISTING DISTRIBUTION BOARD TO REMAIN AS IS.			T1
MSSB		NEW MSSB PROVIDED AS PART OF THE MECHANICAL SERVICES SUB CONTRACT. COORDINATE THE CONNECTION OF THE SUBMAIN TO THE MSSB AND THE LOCATION OF THE COMMUNICATIONS OUTLETS WITHIN THE MSSB WITH THE MECHANICAL SERVICES SUB CONTRACTOR.			T1
COMMUNICATIONS RACK CR-C		EXISTING CAMPBELL CENTRE COMMUNICATIONS RACK TO BE RELOCATED AS PER THE NOTES.			T1
COMMUNICATIONS RACK CR-A		EXISTING JUNIOR SCHOOL ADMINISTRATION COMMUNICATIONS RACK TO REMAIN AS IS			T1
COMMUNICATIONS RACK CR-D		EXISTING COMMUNICATIONS RACK TO REMAIN AS IS.			T1
COMMUNICATIONS RACK CR-G		EXISTING COMMUNICATIONS RACK TO REMAIN AS IS.			T1
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO A CAT 6 PATCH PANEL IN COMMUNICATIONS RACK CR-C VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL U.N.O	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL ICONIC SERIES	T1
PLUG		CEILING MOUNTED UNLESS NOTED OTHERWISE RJ45 CAT-6 COMMUNICATIONS PLUG FOR VAPE SENSOR / CCTV CAMERA, CABLED BACK THE CAT 6 PATCH PANEL IN CR-C VIA PURPLE 4-PAIR CAT-6 UTP CABLE. PROVIDE THE PLUG SUCH THAT IT PROTRUDES OUT 150MM FROM A FLUSH CONDUIT TO ALLOW THE SENSOR / CAMERA TO BE INSTALLED OVER THE CONDUIT WITH THE PLUG DIRECTLY CONNECTED INTO THE CONCEALED REAR OF THE DEVICE.			T1
EXISTING FIBRE TERMINATION PILLAR		EXISTING FIBRE TERMINATION PILLAR TO REMAIN AS IS.			T1



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3857a - ACGS - CAMPBELL CENTRE REFURBISHMENT

C3857a-0002(T1).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION T1 - 06 OCTOBER 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
BATTERY CLOCK		BATTERY POWERED WALL CLOCK MOUNTED AT 2400mm AFFL C/W THREE-COLOUR SCREEN PRINTED SCHOOL LOGO. THE CONTRACTOR AGREES TO A CREDIT VARIATION OF \$500.00 FOR ANY CLOCK SUPPLIED WITH THE QUEENSLAND GOVERNMENT LOGO	WHITE	ADINA 3039	T1
DDC PANEL		WITHIN ONE WEEK OF BEING AWARDED THE CONTRACT UNDERTAKE AN INVESTIGATION INTO THE PURPOSE OF THE EXISTING DDC PANEL AND PROVIDE WRITTEN REPORT ON ITS USE.			T1
ACCESS CONTROL CARD READER (CR)		WALL-MOUNTED 1000AFFL VANDAL-RESISTANT ACCESS CONTROL SYSTEM HEAVY-DUTY PROXIMITY CARD READER PROVIDE DOOR READERS AND POWER SUPPLIES AS REQUIRED ALL EXISTING CARD READERS ARE TO BE REPLACED UNLESS NOTED OTHERWISE. ALL CABLING AND CONDUITS ASSOCIATED WITH THE CARD READER IS TO BE CONCEALED.			T1
ACCESS CONTROL DOOR ELECTRIC STRIKE 1 (ES1)		PROVIDE THE DOOR WITH ACCESS CONTROL UTILISING A FLUSH MOUNTED ELECTRIC DOOR STRIKE PLATE. CONNECT THE ELECTRIC STRIKE TO THE ACCESS CONTROL SYSTEM. PROVIDE CONCEALED DOOR READER MODULES & AUXILIARY POWER SUPPLIES AS REQUIRED. EACH ELECTRIC STRIKE DOOR IS TO BE PROVIDED WITH DOOR STATUS REPORTING (DOOR OPEN / DOOR CLOSED) REED SWITCH. ALL CABLING AND CONDUITS ASSOCIATED WITH THE ELECTRIC STRIKE IS TO BE CONCEALED.			T1
SECURITY EQUIPMENT		RELOCATE THE EXISTING SECURITY PANEL / EXPANDERS AND ACCESS CONTROL CONTROLLER AND ASSOCIATED POWER SUPPLIES. PROVIDE AN INTERFACE TO THE SECURITY SYSTEM SUCH THAT THE INTERNAL LIGHTS ARE CONTROLLED VIA A DRY CONTACT FROM THE SECURITY SYSTEM SO THE INTERNAL LIGHTS ARE AUTOMATICALLY TURNED OFF / DISABLED WHEN THE SECURITY SYSTEM IS ARMED. PROVIDE ADDITIONAL SECURITY PANEL / EXPANDERS AND ACCESS CONTROL CONTROLLERS WITH ALL NECESSARY POWER SUPPLIES AS REQUIRED.			T1
INTRUDER DETECTOR SENSOR		DUAL-TECHNOLOGY MOVEMENT DETECTORS WALL MOUNTED AS PER THE MANUFACTURER'S SPECIFICATION. CONNECT TO THE LOCAL SECURITY EQUIPMENT WITH ONE DETECTOR PER ZONE. PROGRAM THE SECURITY SYSTEM TO THE SATISFACTION OF THE CLUB. SUBMIT DETAILS OF THE DETECTORS INCLUDING THE MOUNTING ARRANGEMENTS FOR APPROVAL PRIOR TO ORDERING.			T1
SECURITY PIEZO		FLUSH RECESSED SECURITY SYSTEM PIEZO SIREN	WHITE	Hills WP05	T1
PA SYSTEM RECESSED SPEAKER		15W CEILING RECESSED MULTI TAP 100V 8 OHM PUBLIC ADDRESS DUAL CONE SPEAKER CABLED BACK IN STAR CONFIGURATION TO AN AMPLIFIER WITHIN THE ASSOCIATED COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE UNLESS NOTED AS BLACK (BK)	AUSTRALIAN MONITOR QF8CS	T1
PA SYSTEM SURFACE MOUNTED SPEAKER		5W SURFACE MULTI TAP 100V 8 OHM PUBLIC ADDRESS DUAL CONE SPEAKER CABLED BACK IN STAR CONFIGURATION TO AN AMPLIFIER WITHIN THE ASSOCIATED COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE UNLESS NOTED AS BLACK (BK)	AUSTRALIAN MONITOR ATC5404	T1

C3857a-0002(T1).xls

Pages inc. any attach. 5 of 6



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3857a - ACGS - CAMPBELL CENTRE REFURBISHMENT

C3857a-0002(T1).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION T1 - 06 OCTOBER 2026

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PA SYSTEM HORN		30W SURFACE MOUNTED ADJUSTABLE IP66 MULTI TAP 100V 8 OHM PUBLIC ADDRESS HORN SPEAKER CABLED BACK IN STAR CONFIGURATION TO AN AMPLIFIER WITHIN THE ASSOCIATED COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE UNLESS NOTED AS BLACK (BK)	AUSTRALIAN MONITOR SH30	T1
FIRE INDICATOR PANEL (FIP)		EXISTING FIRE INDICATOR PANEL TO BE REPLACED WITH AN AS 1670 COMPLAINT FIRE INDICATOR PANEL INCORPORATING THE EWCIE AND FDCIE THE FIP IS TO BE THE SAME BRAND AS THAT USED IN THE EXISTING CENTENARY BUILDING. NETWORK THE NEW FIP INTO THE SCHOOLS EXISTING BRIGADE MONITORED FIRE ALARM SYSTEM VIA THE EXISTING FIBRE CABLE FROM CR-C.			T1
FIRE ALARM VISUAL ALARM DEVICE		WALL MOUNTED FIRE ALARM VISUAL ALARM STROBE LIGHT AS PER AS1670.1			T1
SMOKE DETECTOR		SURFACE MOUNTED AS7240.7 POINT SMOKE DETECTORS WITH A PERFORMANCE OF 6 TO 12 % OBS/M SET AT 7.8 %. WHITE UNLESS NOTED AS BLACK (BK) CAGE DEMOTES THE DETECTOR IS TO BE PROVIDED WITH A GALVANIZED STEEL CAGE TO PROTECT THE DETECTOR FROM IMPACTS FROM BASKET BALLS.			T1
THERMAL DETECTOR		SURFACE MOUNTED AS7240.5:2018 TYPE B SEALED FIXED TEMPERATURE ADDRESSABLE THERMAL DETECTOR. WHITE UNLESS NOTED AS BLACK (BK)			T1
FIRE EVACUATION HORN		SURFACE MOUNTED TWO-TONE 30W ALERT AND EVACUATION HORN SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER. MOUNT AT HIGH LEVEL.			T1
FIRE EVACUATION RECESSED SPEAKER		RECESSED 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE PAINTED OUT TO MATCH THE CEILING.			T1
FIRE EVACUATION SURFACE SPEAKER		SURFACE MOUNT 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND GRILLE PAINTED OUT TO MATCH THE CEILING.			T1